

COMMONWEALTH OF MASSACHUSETTS
DEPARTMENT OF TELECOMMUNICATIONS AND ENERGY

)	
TOWN OF FRAMINGHAM REQUEST FOR)	
DETERMINATION OF RATES APPLICABLE TO)	D.T.E. 02-46
TRANSPORTATION AND TREATMENT OF SEWAGE)	
PURSUANT TO INTERMUNICIPAL AGREEMENT)	
)	

**TOWN OF FRAMINGHAM'S RESPONSE TO
THE DEPARTMENT'S EIGHTH AND NINTH RECORD REQUESTS**

The Town of Framingham ("Framingham") responds to the DTE's eighth and ninth record requests as follows.

Record Request No. 8 (September 23, 2003, Tra. at 871-72)

Please provide a list of all sewer pipelines utilized to transport Ashland's flow during dry-weather conditions.

Response to Record Request No. 8

Based upon a visual inspection of accessible pipes, existing metering data, and existing maps, SEA has identified the following pipes as carrying Ashland's flow during dry weather conditions. The pipe lengths identified are based on GIS mapping using field verified manhole locations. Pipes marked with a (*) indicate a pipe which is at least in part a parallel pipe.

Bates Road to Eames Street	
Size of Pipe	Length of Pipe
18	4250

feet

Eames Street to Beaver Street	
Size of Pipe	Length of Pipe
14	90
18	900*
24	1285*
30	1510

feet
feet
feet
feet

Beaver Street to Waverley	
Size of Pipe	Length of Pipe
30	50
42	3138

feet
feet

Farm Pond from Ashland Discharge to Bishop Street	
Size of Pipe	Length of Pipe
36	3358

feet

Bishop Street to Beaver Street	
Size of Pipe	Length of Pipe
36	1075
TOTAL	15656

feet
feet

This response was provided by Stephen Geribo and Paul
Brinkman of SEA Consultants, Inc.

Record Request No. 9 (September 23, 2003, Tra. at 872)

Please provide a copy of the DEP guidance document referenced during Mr. Geribo's rebuttal testimony.

Response to Record Request No. 9

Please see document provided. This document was printed from the DEP's web site, and certain formatting errors were corrected. The document in its original format is available at <http://www.state.ma.us/dep/brp/mf/files/wwtrfpg.doc>.

This response was provided by Stephen Geribo and Paul Brinkman of SEA Consultants, Inc.

Respectfully submitted,
THE TOWN OF FRAMINGHAM,
By its attorneys,

Christopher J. Petrini
Erin K. Higgins
Conn Kavanaugh Rosenthal Peisch
& Ford, LLP
Ten Post Office Square
Boston MA 02019
(617) 482-8200
(617) 482-6444 (fax)

DATED: September 30, 2003

184661.1